

City of Wichita, Kansas

Americans with Disabilities Act Transition Plan

Finlay Ross Park

123 West Douglass

August 2005



Prepared by

DMCG

Disability Management Consulting Group L.L.C.

2801 Jonquil Place

Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed <i>(Include initial)</i>
1. Pedestrian Path	An accessible path of travel does not exit leading to the park and park benches due to steps.	4.3.2	According to ADAAG, at least one accessible route shall connect accessible buildings, facilities, elements, and spaces that are on the same site. In addition, if an accessible route has changes in level greater than 1/2 in (13 mm), then a curb ramp, ramp, elevator, or platform lift (as permitted in 4.1.3 and 4.1.6) shall be provided that complies with 4.7 , 4.8 , 4.10 , or 4.11 , respectively. An accessible route does not include stairs, steps, or escalators. Ensure that an accessible path of travel exists leading to the park.	L H	H	M	0 1	\$300	ADAAG			
			Only benches exist in the park area.									

Finley Ross Park - Conceptual Cost Projections	
Total	\$300
Year One (Very High)	\$0
Year Three (High)	\$0
Year Five (Medium)	\$300
Year Ten (Low)	\$0